

System Resilience Against Major Earthquakes

~Learnings from the Hokkaido Blackout~

May 14th 2019

Manabu Nabeshima

1. Background

2. Fact-sharing


3. Implication

Where Hokkaido is



International comparison of the grid size


(Summer Peak Load)



US: EIA Annual Energy Review 2012
Europe: ENTSO-E Statistical Factsheet 2017
Japan: METI Demand and Supply Review Nov 2018

Interconnection between control areas

- Japan has limited interconnection capacity between the 9 control areas.



*DC: direct current, FC: frequency conversion

1. Background


2. Fact-sharing

3. Implication

Demand scale when the earthquake hit

- The earthquake hit Hokkaido when the demand was relatively small

Monthly peak demand; MWh, 2017




Hourly demand on the day of EQ; MWh



The epicenter of the earthquake

- The epicenter was close to Tomato-Atsuma thermal power plant

Grid map of Hokkaido




Source of supply before the EQ

Generation type	Output (MWh)	Share
Thermal	1,725 (1,492 from Tomato-Atsuma)	56%
Hydro	780	25%
Wind	166	5%
Solar	0	0%
Interconnection	72	2%
Others	344	11%
Total	3,087	

Sequence of events that led to the blackout

- 3 units at Tomato-Atsuma (N-3) shut down
- 4 power transmission lines (N-4) were damaged by ground fault.
- The UFR* and interconnection were insufficient to sustain the frequency

*UFR: Under Frequency Relay




Tomato-Atsuma power plant




Transmission accident

Earthquake vibrations caused the [1] jumper wire to come in contact with the [2] tower body



Recovery from the blackout


- It took approx. 45 hours to supply power to nearly the entire area



Voluntary power saving

- METI asked the citizens of Hokkaido to cut back electricity demand from 8:30 to 20:30 and 10~20% of reduction was achieved

Electricity demand reduction rate



*Demand is measured against the peak demand during Sep.5th, the day before EQ

Measures to be taken



Expansion of the interconnection capacity



Addition of load shedding capacity (UFR: Under Frequency Relay)



Ensuring resource adequacy

1. Background

2. Fact-sharing

3. Implication

Implication to Renewable Energy Sources (RES)



On-site PV contributed to support household demand. **Educating the citizens** on how to modify the device setup is important



Clear grid code is required to make RES more resilient to frequency changes



Sufficient balancing capacity is required for RES to re-connect to the grid after blackout

Contribution of on-site Solar Photovoltaic (PV)

- METI announced how to modify the device setup to run in power from the on-site PV


Announcement from METI

- 自立運転機能の使用方法是、概ね以下のとおりだが、メーカーや機種により操作方法が異なる場合があるので、取扱説明書の確認が必要。


- ① 自立運転用コンセント（茶色のコンセントが目印）の位置を確認し、取扱説明書で「自立運転モード」への切り替え方法を確認する。
- ② 主電源ブレーカーをオフにし、太陽光発電ブレーカーをオフにする。
- ③ 「自立運転モード」に切り替え、自立運転用コンセントに必要な機器を接続して使用する。

※ 停電が復旧した際は、必ず元に戻す。（自立運転モード解除⇒太陽光発電用ブレーカーをオン⇒主電源ブレーカーをオンの順で復帰）

<ソーラーフロンティアの例>




Share of households utilized on-site PV during the blackout



Resilience against frequency changes

- Due to mechanical configuration, 170MW of wind power tripped all at once when the frequency dropped below approx. 47.0Hz.



Recovery of RES

- It took a week for RES to recover to full operation due to lack of balancing capacity

